

CERTIFICATE OF COMPLIANCE

Certificate Number 20190225-EX6960
Report Reference EX6960-20110729
Issue Date 2019-FEBRUARY-25

Issued to: FIREPRO SYSTEMS LTD
6, Koumandarias Street
& Spyrou Araouzou
Tonia Court No. 2, 1st Floor 3036
54080 Limassol CYPRUS

**This certificate confirms that
representative samples of**

FIXED CONDENSED AEROSOL EXTINGUISHING
SYSTEM UNITS

Please see addendum page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 2775, Fixed Condensed Aerosol Extinguishing System
Units
UL514B/CSA C22.2 No 18.3/NMX-J-017-ANCE, Conduit,
Tubing, and Cable Fittings


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number 20190225-EX6960
Report Reference EX6960-20110729
Issue Date 2019-FEBRUARY-25

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Pre-Engineered FirePro Aerosol Generating Fire Extinguishing System Units, Models FP-20SE, FP-20T, FP-40S, FP-40T, FP-80S, FP-80T, FP-100S, FP-200S, FP-500S, FP-1200, FP-1200S, FP-1200T, FP-1200TS, FP-2000, FP-2000S, FP-2000T, FP-2000TS, FP-3000, FP-3000S, FP-3000T, FP-3000TS, FP-4200T, FP-4200TS, FP-5700, FP-5700S, FP-5700T, and FP-5700TS with 20, 40, 80, 100, 200, 500, 1200, 2000, 3000, 4200, and 5700 grams respectively.

These units have an operating temperature range of -65°F (-54°C) to 130°F (54°C). The units are designed for total flooding protection against Class A, ordinary combustibles, Class B flammable liquid fires, with or without Class C involvement, occurring within an enclosure.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

